

MoM of Pre-bid Meeting cum Corrigendum

Name of the work: Augmentation, revamping and refurbishment of various electromechanical systems of Intake area under Garulia Water Supply Scheme.

e-Tender No.:SE(E/M)-II/T-01 of 2024-25 Dt.11/06/2024

Sl No.	Section, page, clause etc.	In place of (existing)	Shall be read as
1	No prospective bidder was present in the pre-bid meeting dt.03/07/2024, 14:00 hours		
2	Section-E, Clause 1.0 Vertical Wet Pit Pumps, 1.1.1	'with suitable cassion pipe'	'with suitable new cassion pipe/s if the existing one/s does/do not serve the purpose (if served, old one/s will be used with addition/alteration as per site-conditions) as per the EIC'.
3	Section-E, Clause 1.0 Vertical Wet Pit Pumps, 1.1.8	'It shall have one suitable cassion pipe/s preventing entry'	'It shall have suitable new cassion pipe/s if the existing one/s does/do not serve the purpose (if served, old one/s will be used with addition/alteration as per site-conditions) as per the EIC, to prevent entry'

Sd/- 11/07/2024

Superintending Engineer (E/M)-II